



OFFICE OF THE DISTRICT FIRE OFFICER,  
HUBLICITY FIRE STATION HUBLI 580024

C.N.03/CC/DFO/HUBLI CITY/2025

Date: 17/03/2025

To,  
Principal  
New Education Society ®  
Gyan Bharati English Medium School  
Deshpande Nagar, Hubli-580029

Sir,

Sub : Issue of "**Fire Safety Compliance Report**" with respect to Fire Prevention, Fire Fighting And Evacuation measures maintained/Required at New Education School Society ® Gyan Bharati English Medium School At Deshpande Nagar, Hubli-580029

Ref : 1) This Office Advice Certificate C.No.02/ADV/DFO/HUBLI CITY/2025

Date: 14-03-2025

2) Applicant request letter dated 17/03/2025

3) C.No.09/FSO/HFS/2025 Date-17-03-2025

><<<\*@\*<<<<

With reference to the subject above cited, above, "Fire Safety Recommendation" was issued wide reference (1) to the premises of "New Education Society ® Gyan Bharati English Medium School At Deshpande Nagar, Hubli-580029" with a condition to fulfil the recommendation and Compliance the same within 03 Months.


With reference cited (2) above the Mangement of the "New Education Society ® Gyan Bharati English Medium School At Deshpande Nagar, Hubli-580029" had requested for the Compliance Certificate from our Department. In this Regard Fire Station Officer Hubli City Fire Station was Inspected the Premises on 17-03-2025 And Submitted the report to issue of Compliance Certificate.

Under the Above circumstances & the report submitted by the Fire Station Officer Hubli City Fire Station, The Karnataka State Fire And Emergency Services Department is issuing the 'Fire Safety Compliance Report' at "New Education Society ® Gyan Bharati English Medium School At Deshpande Nagar, Hubli-580029" subject to Proper maintenances of fire fighting installations in good working condation and to renew the Fire Safety Recommendation report for every Year.

**"This Report is vaild for One Year From the Date of Issue and is renewable without fail"**

Note:40% of the available staff should be trained at R.A. Mundakur Fire Service Academy Bangalore so as to operate the Extinguishers in case of Emergency within the Period of three months.

Yours Faithfully

  
17/03/25  
**District Fire Officer**  
Karnataka Fire & Emergency Service  
Fire Station, Hubli City,  
HUBBALLI-580024

Copy:

01) Fire Station Officer Hubli City Fire Station.



**OFFICE OF THE DISTRICT FIRE OFFICER,  
HUBLICITY FIRE STATION HUBLI 580024**

**C.N.02/ADV/DFO/HUBLI CITY/2025**

**Date: 14/03/2025**

To,  
Principal  
New Education Society ®  
Gyan Bharati English Medium School  
Deshpande Nagar, Hubli-580029

Sir,

Sub : Issue of 'Fire Safety recommendation/Advice' to New Education Society ®  
Gyan Bharati English Medium School at Deshpande Nagar, Hubli-580029

Ref :1) Applicant request letter dated 12/03/2025  
2) C.No.07/FSO/HFS/2025 Date-13-03-2025

><<<\*@\*<<<<

With reference to the subject above cited, the premises of New Education Society ®  
Gyan Bharati English Medium School building consisting with Ground floor + 1 upper floor  
situated on Deshpande Nagar, Hubli-580029 was inspected by the Fire Station Officer,  
Hubli City on 12/03/2025 with respect to Fire prevention, Fire fighting and Evacuation  
measures to be complied in the above premises and has submitted the details as under.

**ANNEXURE-1**

**(Up to 14.99 mtrs in height)**

**Group B Education Building**

***NBC-2016, part-4, table 7 (11) 3.1.3 Group B Educational Building Sub division B 1.& B2.***  
**(These condition are indicative and not exclusive all relevant provisions related to fire  
and life safety of NBC 2016 are mandatory)**

**A. Details of the building / premises :-**

01	Name and Address of the Applicant.	:	Principal New Education Society ® Gyan Bharati English Medium School Deshpande Nagar, Hubli-580029
02	Name and Address of the premises.	:	New Education Society ® Gyan Bharati English Medium School Deshpande Nagar, Hubli-580029
03	Name and address of the Building owner	:	Principal New Education Society ® Gyan Bharati English Medium School Deshpande Nagar, Hubli-580029

04	Number of buildings	:	One building
05	Number of floors	:	Ground +01 upper Floor
06	<b><u>Floor-wise details of occupancy:-</u></b>		
	Ground floor	:	04 Class room
	1 <sup>st</sup> floor	:	04 Class room
07	Height of the building	:	10.50 Mtrs
08	Site area	:	8197.41 Sq. Mtrs
09.	<b>Built-up area of each floor:-</b>		
	Ground floor	:	332.30 Sq. Mtrs.
	1 <sup>st</sup> floor	:	332.30 Sq. Mtrs.
10.	<b>Total built-up area</b>	:	<b>664.60 Sq. Mtrs.</b>
11.	<b>Surrounding properties:-</b>		
	North (Front)	:	Play Ground
	South (Rear)	:	Government Property
	East (Side)	:	Open Site
	West (Side)	:	18.00 Mtr Wide Approach Road
12.	<b><u>Set-back area available around the building :-</u></b>		
	North (Front)	:	More than 05.00 Mtr
	South (Rear)	:	03.50 Mtr
	East (Side)	:	04.56 Mtr
	West (Side)	:	04.30 Mtr

**NOTE:** Recommended to provide and maintain setbacks as per Local ZR.

B. On inspection of this Educational premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)
-------------	--------------	---------------	----------------------

01.	Accessibility to the premises	The premises is abutting by 18.00 mtrs. Wide road located on Western		Adequate
02.	No. of entrances	01 Enrtry & 01 Exit		Adequate
03.	Width of entry / exit	01 Enrty 06.15 Mtrs. 01 Exit 04.50		Recommended to Provide Minimum 06.00 mtrs. Width with height clearance of minimum 05.00 mtrs from ground level.
04.	Diesel generators.	.....		Recommended to provide Diesel Generator of adequate capacity
05.	No. of staircases available	Nos. of staircases	: 02	Rcommended to provided staircases maintain travel distance with 22.50 mtrs. With minimum 02.00 mtrs width, 30 mm treads width, 15 mm treads height, 1 mtr. Handrail with minimum 02.20 head room clearance
		Width of staircases	: 01.60 m	
		Width of treads	: 29 cm	
		Height of risers	: 16 cm	
		Nos. of riser per flight	: 13 nos	
		Height of handrails	: 00.92 Mtr	
		Head room clearance	: 03.91	
06.	No. lifts and capacity.	Nos. of lifts	: --	N/A
		Capacity of lifts	: --	
07.	Fire extinguisher	.....		A. One water mist extinguishers of 9 ltrs capacity should kept near each staircase landing. B. One mechanical foam extinguisher of 9 ltrs capacity & One ABC type extinguisher of 6 kgs capacity should be provided near Diesel generator.

			<p>C. One CO2 type fire extinguisher of 4.5 kgs capacity should be provided near each electrical panel board &amp; electrical room.</p> <p>D. One ABC type fire extinguisher of 06 kgs capacity should be available within 15 mtrs. radius</p>
08.	Public address system	-----	Recommended to provide public address system with talk back facility at each floor of College building with its 'Control' at the ground floor level at Security room.
09.	First aid Hose reel hose.	-----	Hose Reel Hose near the staircase ( <b>One hose reel hose system for every 1000 sq. mtrs</b> ) The hose reel hose of min 19 mm size and of 30.00 mtrs length shall be provided to reach the farthest point of each floor and shut off branch having a nozzle of 5mm size. The hose reel hose should be connected at each landing of each building/block/wing/tower.
10.	Terrace tank over respective tower terrace.	-----	Terrace tank required 10,000 ltrs. Capacity <b>(the water tank should be kept exclusively fire fight purpose)</b>
11.	Pump at the terrace tank level with minimum pressure of 3.5 kg/cm <sup>2</sup> . ----	-----	Recommended to provide booster pump of 450 lpm capacity.
12.	Fire control room at ground floor.	-----	Recommended to Provide Fire control room at the entrance/security room.
13.	Escape routes	-----	Recommended to provide Direction in which the students have to move in the event of an emergency should be displayed in the corridor on each floor during evacuation.
14.	Fire order	-----	Fire safety plans has to be indicated with details of actions to

Fire C  
 Hubli  
 580024  
 panel

			be taken in case of fire emergency near staircase landing at each floor with telephone numbers of <b>Hubli city fire station i.e., 0836-2240789 &amp; 101</b> telephone numbers of the nearest Amulance service & police Station.
15.	Fire fighting training	-----	At-least 40% of Teaching and Non Teaching staff should be got trained in should be got trained in basic fire fighting at R.A. Mundkur Fire and Emergency Services Academy, Bannerughatta road. Bangalore or Regional Training Centre
16.	No smoking board	-----	COTPA Sec-4 direcation NO smoking area smoking here is an offence board should be written in English & Kannada both language shall be prominently displayed at inside the entry/exit of the each floor
17.	Fire Siren	-----	A Fire siren shall be installed in the Premises to inform the inmates in case of a fire emergency and evacuate the area.
18.	Nominate One Fire Nodal Officer	-----	A fire nodal Officer shall be nominted either from teaching or non teaching staff
19.	Fire precautionary measures:- A. Exposive and Flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises. B. Accumulation of combustibile waste in and around the premises should be avoided. C. The exit ways shall be always kept clear without any obstruction. D. Liquefied petroleum gas should not be stored in the building. E. The doors shall not be kept locked/latched during working hours and shall be free from obstruction. F. During the class hours the class room doors shall not be locked from inside to		

out side.

As per Hon'ble supreme court order all teachers and staffs shall be trained to handle safety equipments, initiate emergency evacuation and protect their students in the event of fire and other emergency And the school shall observe the Fire Safety DAY ON April 14<sup>th</sup> of every year by conducting Fire Safty drills with Co-ordinate with fire service department.

The Karnataka Fire & Emergency Service Department is issued the Fire Safety recommendation in compliance to the undersigened, within 90 days.

- All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.4 of Fire and Life safety will have to be complied with mandatorily.

From the above details it is clear that the '**Management**' of the above Educational building have been recommended to provide fire precautionary measures as per *National Building Code 2016, part-4, Table 7 (11) 3.13 Group B Educational Buiding Sub division B1 & B2*. After full – filling the above recommendations, a Certificate should be obtained by this office . *if any time any of the conditions are found not complied with, this Certificate shall stand withdrawn/cancelled.*

Hence , on the report submitted by the me this recommendation Certificate is issued to New Education Society ® Gyan Bharati English Medium School building consisting with Ground +1 upper floors situated on Deshpande Nagar, Hubli-580029

**This certificate is valid for a period of one year from the date of issue of this letter and is renewable.**

Yours faithfully

Copy to the 01) Fire Station Officer Hubli City.

  
14/03/25  
District Fire Officer  
Karnataka Fire & Emergency Service  
Fire Station, Hubli City,  
HUBBALLI-580024